



[별 첨1] 측정 위치도(측정 장소)

여수캠퍼스 도서관 및 교양관 석면철거공사 <도서관>




범례	*NO		
	시료채취	부지경계선	해당건물

[별첨2] 측정 결과

시료 번호	측정 지점	측정 장비 (종류/수량)		유량 (ℓ/분)	측정 일시	측정 결과 (f/cc)	비고
1	부지경계선1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
2	부지경계선2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
3	부지경계선3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
4	부지경계선4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
5	위생설비입구	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
6	작업장주변1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
7	작업장주변2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
8	음압기배출구1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
9	음압기배출구2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
10	음압기배출구3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
11	음압기배출구4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
12	음압기배출구5	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/08	불검출 [검출한계 0.002미만]	-
-	공시료	-	-	-	-	0개/100개시야	-
-	공시료	-	-	-	-	0개/100개시야	-



[별첨3] 측정 사진

측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
부지경계선1,2				
	시작시간: 11:00	종료 시간: 15:00	시작시간: 11:02	종료 시간: 15:02
부지경계선3,4				
	시작시간: 11:05	종료 시간: 15:05	시작시간: 11:07	종료 시간: 15:07
위생설비입구/ 작업장주변1				
	시작시간: 11:15	종료 시간: 11:55	시작시간: 11:20	종료 시간: 13:20
작업장주변2/ 음압기배출구1				
	시작시간: 11:25	종료 시간: 13:25	시작시간: 13:05	종료 시간: 13:45
음압기배출구2,3				
	시작시간: 13:30	종료 시간: 14:10	시작시간: 13:30	종료 시간: 14:10
음압기배출구4,5				
	시작시간: 14:20	종료 시간: 14:10	시작시간: 14:20	종료 시간: 15:00

[별 첨1] 측정 위치도(측정 장소)

여수캠퍼스 도서관 및 교양관 석면철거공사 <도서관>






범 례	*NO		
	시료채취	부지경계선	해당건물

[별첨2] 측정 결과

시료 번호	측정 지점	측정 장비 (종류/수량)		유량 (ℓ/분)	측정 일시	측정 결과 (f/cc)	비고
1	부지경계선1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
2	부지경계선2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
3	부지경계선3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
4	부지경계선4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
5	위생설비입구	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
6	작업장 주변1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
7	작업장 주변2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
8	음압기배출구1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
9	음압기배출구2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
10	음압기배출구3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
11	음압기배출구4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
12	음압기배출구5	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
13	폐기물반출구	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/09	불검출 [검출한계 0.002미만]	-
-	공시료	-	-	-	-	0개/100개시야	-
-	공시료	-	-	-	-	0개/100개시야	-

[별첨3] 측정 사진



측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
부지경계선1,2				
	시작시간: 9:30	종료 시간: 13:30	시작시간: 9:33	종료 시간: 13:33
부지경계선3,4				
	시작시간: 9:37	종료 시간: 13:37	시작시간: 9:42	종료 시간: 13:42
위생설비입구/ 작업장주변1				
	시작시간: 9:55	종료 시간: 10:35	시작시간: 10:02	종료 시간: 12:02
작업장주변2/ 음압기배출구1				
	시작시간: 10:07	종료 시간: 12:07	시작시간: 10:20	종료 시간: 11:00
음압기배출구2,3				
	시작시간: 10:21	종료 시간: 11:01	시작시간: 10:23	종료 시간: 11:03
음압기배출구4,5				
	시작시간: 11:10	종료 시간: 11:50	시작시간: 11:11	종료 시간: 11:51

측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
폐기물반출구				
	시작시간: 13:15	종료 시간: 13:55	-	-

[별첨1] 측정 위치도(측정 장소)

여수캠퍼스 도서관 및 교양관 석면철거공사 <도서관>






























범례	*NO		
	시료채취	부지경계선	해당건물

[별첨2] 측정 결과

시료 번호	측정 지점	측정 장비 (종류/수량)		유량 (ℓ/분)	측정 일시	측정 결과 (f/cc)	비고
1	부지경계선1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
2	부지경계선2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
3	부지경계선3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
4	부지경계선4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
5	위생설비입구	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
6	작업장주변1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
7	작업장주변2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
8	음압기배출구1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
9	음압기배출구2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
10	음압기배출구3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
11	폐기물반출구1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
12	폐기물반출구2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
13	폐기물반출구3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/10	불검출 [검출한계 0.002미만]	-
-	공시료	-	-	-	-	0개/100개시야	-
-	공시료	-	-	-	-	0개/100개시야	-


[별첨3] 측정 사진



측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
부지경계선1,2				
	시작시간: 9:50	종료 시간: 13:50	시작시간: 9:53	종료 시간: 13:53
부지경계선3,4				
	시작시간: 9:57	종료 시간: 13:57	시작시간: 10:00	종료 시간: 14:00
위생설비입구/ 작업장주변1				
	시작시간: 10:15	종료 시간: 10:55	시작시간: 10:18	종료 시간: 12:18
작업장주변2/ 음압기배출구1				
	시작시간: 10:21	종료 시간: 12:21	시작시간: 10:35	종료 시간: 11:15
음압기배출구2,3				
	시작시간: 10:45	종료 시간: 11:25	시작시간: 10:50	종료 시간: 11:30
폐기물반출구1,2				
	시작시간: 11:20	종료 시간: 12:00	시작시간: 11:25	종료 시간: 12:05

측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
폐기물반출구3				
	시작시간: 13:00	종료 시간: 13:40	-	-

[별첨1] 측정 위치도(측정 장소)

여수캠퍼스 도서관 및 교양관 석면철거공사 <교양관>




범례	*NO		
	시료채취	부지경계선	해당건물

[별첨2] 측정 결과

시료 번호	측정 지점	측정 장비 (종류/수량)	유량 (l/분)	측정 일시	측정 결과 (f/cc)	비고	
1	부지경계선1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
2	부지경계선2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
3	부지경계선3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
4	부지경계선4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
5	위생설비입구	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
6	작업장주변1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
7	작업장주변2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
8	음압기배출구1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
9	음압기배출구2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
10	음압기배출구3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
11	음압기배출구4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
12	음압기배출구5	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
13	음압기배출구6	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
14	폐기물반출구1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
15	폐기물반출구2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
16	폐기물반출구3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
17	폐기물반출구4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/11	불검출 [검출한계 0.002미만]	-
-	공시료	-	-	-	-	0개/100개 시야	-
-	공시료	-	-	-	-	0개/100개 시야	-

[별첨3] 측정 사진



측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
부지경계선1,2				
	시작시간: 8:30	종료 시간:12:30	시작시간:8:32	종료 시간: 12:32
부지경계선3,4				
	시작시간: 8:35	종료 시간:12:35	시작시간:8:36	종료 시간: 12:36
위생설비입구/ 작업장주변1				
	시작시간: 8:45	종료 시간:9:25	시작시간:8:50	종료 시간: 10:50
작업장주변2/ 음압기배출구1				
	시작시간: 8:52	종료 시간:10:52	시작시간:9:00	종료 시간: 9:40
음압기배출구2,3				
	시작시간: 9:20	종료 시간:10:00	시작시간:9:24	종료 시간: 10:04
음압기배출구4,5				
	시작시간: 14:00	종료 시간:14:40	시작시간:14:02	종료 시간: 14:42

측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
음압기배출구6/ 폐기물반출구1				
	시작시간: 14:03	종료 시간: 14:43	시작시간: 10:00	종료 시간: 10:40
폐기물반출구2,3				
	시작시간: 10:25	종료 시간: 11:05	시작시간: 10:40	종료 시간: 11:20
폐기물반출구4				
	시작시간: 15:30	종료 시간: 16:10	-	-

[별 첨1] 측정 위치도(측정 장소)

여수캠퍼스 도서관 및 교양관 석면철거공사 <교양관>





범 례	*NO		
	시료채취	부지경계선	해당건물

[별첨2] 측정 결과


시료 번호	측정 지점	측정 장비 (종류/수량)	유량 (ℓ/분)	측정 일시	측정 결과 (f/cc)	비고	
1	음압기배출구1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/12	불검출 [검출한계 0.002미만]	-
2	음압기배출구2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/12	불검출 [검출한계 0.002미만]	-
3	음압기배출구3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/12	불검출 [검출한계 0.002미만]	-
-	공시료	-	-	-	-	0개/100개 시야	-
-	공시료	-	-	-	-	0개/100개 시야	-
*특이사항 -해체작업이 종료되어 음압기배출구만 측정함.							

[별첨3] 측정 사진

측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
음압기배출구1,2				
	시작시간: 8:30	종료 시간: 12:30	시작시간: 8:32	종료 시간: 12:32
음압기배출구3				
	시작시간: 8:35	종료 시간: 12:35	-	-

[별첨1] 측정 위치도(측정 장소)

여수캠퍼스 도서관 및 교양관 석면철거공사 <교양관>











범 례	*NO	<div></div>	<div></div>
	시료채취	부지경계선	해당건물

[별첨2] 측정 결과

시료 번호	측정 지점	측정 장비 (종류/수량)		유량 (ℓ/분)	측정 일시	측정 결과 (f/cc)	비고
1	폐기물보관지점1	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/13	불검출 [검출한계 0.002미만]	-
2	폐기물보관지점2	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/13	불검출 [검출한계 0.002미만]	-
3	폐기물보관지점3	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/13	불검출 [검출한계 0.002미만]	-
4	폐기물보관지점4	지역시료채취펌프 (SARA-5100)	1	10.00	20/02/13	불검출 [검출한계 0.002미만]	-
-	공시료	-	-	-	-	0개/100개시야	-
-	공시료	-	-	-	-	0개/100개시야	-

[별첨3] 측정 사진

측정 지점	시작 사진	종료 사진	시작 사진	종료 사진
폐기물보관지점1,2				
	시작시간: 14:00	종료 시간: 14:40	시작시간: 14:00	종료 시간: 14:40
폐기물보관지점3,4				
	시작시간: 14:20	종료 시간: 15:00	시작시간: 14:20	종료 시간: 15:00